



TO REMOVE FRONT FILTER, REMOVE TOP SCREW FROM EACH SIDE BRACKET. ROTATE BRACKETS AWAY FROM FILTER, THEN SLIDE FILTER UP AND REPLACE AS NECESSARY.

Notes: Unless otherwise specified, dimensions are in inches. Dimensions within brackets [ ] are in millimeters.  
 Recommended clearance for serviceability is 36" [914] in the front and 6" [152] on the remaining sides.

**LTI Power Systems, Inc.**

ProUPS B2050 ENCLOSURE  
 65KVA

65KVA WEIGHT W/SKID: 3200 LBS. (1440 kg)

LTI-ProUPS

TEL. (440) 327-5050

10800 Middle Ave. Elyria, Ohio 44035

CAD DWG NAME: B2050CAB\_65KVA\_50HZ\_FILTER

REV.

1





